

**FIRE INSPECTOR'S  
INTER-OFFICE CORRESPONDENCE**

**TO:** Genaro Argenio, Planning Board Chairman

**FROM:** Francis Bedetti, Asst. Fire Inspector

**SUBJECT:** ~~PB-08-028~~ 08-12  
Cimorelli Auto Repairs  
SBL:4-2-3.13

**DATE:** September 19,2008

**Fire Prevention Reference Number: FPS-08-028**

A review of the above referenced plan was conducted. This extension would require a sprinkler installation in the entire building  
Ref: Town Code 142-16 (A)